

## Storage Tank Enforcement: U.S. Environmental Protection Agency and Topeka, Kansas Tank Operator Enter into Expedited Settlement Agreement



**Walter Wright, Jr.**  
wwright@mwlaw.com  
(501) 688.8839

08/08/2018

The United States Environmental Protection Agency (“EPA”) and Heartland Park (“HP”) entered into a June 25th Expedited Settlement Agreement (“ESA”) addressing alleged violations of the federal underground storage tank (“UST”) regulations. See Docket No. RCRA-07-2018-0230.

The ESA provides that HP is the operator of an UST in Topeka, Kansas.

The ESA references an inspection of the Topeka, Kansas, UST. Alleged violations identified include:

- Failure to provide adequate line leak detector system for underground piping (mechanical line leak detector removal for STP)
- Failure to provide adequate line leak detector system for underground piping (annual junction test if out of date, last date took place on 10/31/16)

The ESA references a proposed penalty of \$508.00.

A [copy of the ESA](#) can be downloaded here.